## Prüfinstitut Hoch

Lerchenwea 1 D-97650 Fladungen Tel.: int - 49 - 9778-7480-200

hoch.fladungen@t-online.de

www.reaction-to-fire.de



Test laboratory for the fire behavior of building materials, Dipl.-Ing. (FH) Andreas Hoch Testing, supervising and certifying body, authorized by the building supervision authority

## TEST REPORT PZ-Hoch-140782

for the proof of Fire behaviour according to DIN 4102, part 1 Translation of the German test report – no guarantee for translation of technical terms

company

DHJ INTERNATIONAL

1, rue de Morat - B.P. 8

67601 SELESTAT Cedex - FRANCE

description of samples

-fabric consisting of polyester with acrylic coating on one side-

colour: white

name of the material

"Decoprint Pearl Oeko-Tex 100"

sampling

by the company itself

content of request

Proof of flammability to classify building materials to class B1

"schwerentflammbar" according to DIN 4102, part 1

validity of test report

31.05.2019

result

ວ່າ.ບວ.ຂບາອ The examined product meets the requirements of class B1 for "schwerentflammbare" (hardly flammable) building materials according to DIN 4102, part 1 (May 1998), suspended freely or with distance of >40 mm to same or other plain materials.

This test report includes 4 pages and 4 enclosures.

Remark: If the above mentioned building material is not used as product according to MBO § 2, Abs. 9, Ziffer1, there is no need for a general building supervisory test report.

This test report is not valid if the examined building material is used as product in the meaning of state building prescriptions (MBO § 17, Abs. 3).

This test report does not replace an eventually necessary proof of applicability concerning building supervisory or building laws in the meaning of state building prescriptions. This has to be verified by:

"allgemeine bauaufsichtliche Zulassung" (general building inspectorate approval) or by "allgemeines bauaufsichtliches Prüfzeugnis" (general building inspectorate certificate) or by "Zustimmung im Einzelfall" (exceptional approval)

This test report can underlie building supervisory procedures

for regular building products for the prescribed proofs of conformity

for non regular building products for the needed proofs of applicability.

This test report must not be published and copied without preceding agreement of the test laboratory and if agreed, only during validity and unchanged concerning appearance and contents.

member of notified body no.: 1508

By the DAkkS according to DIN EN ISO/IEC 17025 accredited test laboratory. The accreditation is valid for the testing methods specified in the certificate.

( DAkkS Deutsche Akkreditierungsstelle D-PL-11005-01-00